
2023 REGIONAL EFFICIENCY STANDARDS



AIR CONDITIONERS - SPLIT SYSTEMS

AIR CONDITIONERS - SPLIT SYSTEMS									
US NORTH AND CANADA		SOUTHEAST		SOUTHWEST					
(Includes Alaska)		(includes Hawaii, Puerto Rico and							
		U.S. Territories)							
SEER2		SEER2		SEER2					
Up to 3.5 tons (less than 45 kBtuh)	13.4	Up to 3.5 tons (less than 45 kBtuh)	14.3	Up to 3.5 tons (less than 45 kBtuh)	14.3				
Over 4 tons (greater than 45 kBtuh)	5 kBtuh) 13.4 Over 4 tons (greater than 45 kBtuh) 1		13.8	Over 4 tons (greater than 45 kBtuh) 13.8					
				¹ EER2					
				Up to 3.5 tons (less than 45 kBtuh)	11.7				
				Over 4 tons (greater than 45 kBtuh)	11.2				
13ACX → N018, N024, N030, N036, N042,									
N048, N060									
16ACX → (all models)									
EL16XC1 → -018, -024, -030, S036, -041,									
-042, -047, -048, -060									
EL17XC1 → (all models)		EL17XC1 → (all models)		EL17XC1 → (all models)					
EL18XCV → S024, S036, S048, S060		EL18XCV → S024, S036, S048, S060		EL18XCV → -024, -036, -048, -060					
EL23XCV → (all models)		EL23XCV → (all models)		EL23XCV → (all models)					
ML14XC1 → S018, S024, S030, S036, S042,									
-041, -047, -048, -059, -060									
ML17XC1 → (all models)		ML17XC1 → (all models)		ML17XC1 → (all models)					
ML18XC2 → (all models)		ML18XC2 → (all models)		ML18XC2 → (all models)					
SL28XCV → (all models)		SL28XCV → (all models)		SL28XCV → (all models)					
XC13 → N018, N024, N030, S036, N042,									
N048, N060									
XC20 → (all models)		XC20 → (all models)		XC20 → (all models)					
XC21 → (all models)		XC21 → (all models)		XC21 → (all models)					

¹ EER2 can be 9.8 if SEER2 is more than 15.2. Efficiency ratings depend on the actual system match-up.

HEAT PUMPS - SPLIT SYSTEMS

US NORTH AND CANADA		SOUTHEAST/ SOUTHWEST			
	(Includes Alaska)	(includes Hawaii, Puerto Rico, U.S. Territories)			
	SEER2 = 14.3	SEER2 = 14.3			
	HSPF2 = 7.5	HSPF2 = 7.5			

NOTE - All Heat Pumps can be sold in all areas. Efficiency ratings depend on the actual system match-up.

PACKAGED ELECTRIC/ELECTRIC, GAS/ELECTRIC			PACKAGED HEAT PUMPS			
NORTH	SOUTHEAST	SOUTHWEST	NORTH	SOUTHEAST	SOUTHWEST	
SEER2 = 13.4	SEER2 = 13.4	SEER2 = 13.4	SEER2 = 13.4	SEER2 = 13.4	SEER2 = 13.4	
		EER2 = 10.6	HSPF2 = 6.7	HSPF2 = 6.7	HSPF2 = 6.7	